



EXCELSIOR FIRE DISTRICT

24100 SMITHTOWN ROAD ★ **SHOREWOOD, MN 55331**

Criteria for EFD Plan Review

All projects/construction must meet:

Minnesota State Fire Code 2015

Adopted by the State of Minnesota in May, 2, 2016

Minnesota State Residential Code 2012

NFPA 13 2010 Edition

NFPA 13D 2002 Edition

NFPA 13R 2010 Edition

NFPA 72 2010 Edition

The Excelsior Fire Districts is made up of five cities: Excelsior, Deephaven, Greenwood, Shorewood, and Tonka Bay.

The Excelsior Fire Districts does not issued building, fire sprinkler, or fire alarms permits. See below for details on the individual cities for permits related to existing or new construction.

Note: The 55331 zip code is for mailing purposed and encompasses many cities. The zip code is not exclusive to the 5 cities in the Excelsior Fire district. Verify the city your project is in.

The Excelsior Fire District requires and issues Tank Removal, Insulations, and Abandonment Permits for all five cities. Contact Kellie Murphy Ringate @ 952-960-1692

Minnesota Rules 1306-Buildings 2000 square feet or more

Adopted by the City of Excelsior, Greenwood, Shorewood, and Tonka Bay.

Plan Review

Contact info required for the person (s) overseeing the project/construction.

NEW CONSTRUCTION

Plan required to be reviewed by the Excelsior Fire District:

Fire Sprinkler Systems

- Commercial
- Residential

Buildings Plans Buildings

Fire Alarm System Plans

EXISTING CONSTRUCTION

Plans subject to review by the Excelsior Fire District:

Tenant Build Outs

Building or Space Remodels

Fire Sprinkler System reconfiguration, additions and changes

- Plans required for 20 or more changes, additions, or changes to fire sprinkler heads

Fire Alarm Systems

- New Installs
- Fire Alarm Panel Replacements
- Upgrades

Plan reviews require 14 business days to review from the date the plans, hydraulic calculations, data sheets, and other required documents are received by the Excelsior Fire District. All items listed above must be received before plans will be reviewed.

Note: The Excelsior Fire District will keep the items mentioned above for our records.

Plans from all five cities are review in the order they are received and not by the size of the job or square footage of the building.

Plans must be submitted to the City of Excelsior, Deephaven, Greenwood, Shorewood, and Tonka Bay for a permit. The Excelsior Fire District does not issue building, fire sprinkler system, or fire alarm system permits.

PERMITS ISSUED BY CITIES

City	Fire Sprinkler System Install	Fire Sprinkler System Modification	Fire Alarm System Install	Fire Alarm System Modification
Excelsior	X	X	X	X
Deephaven	X	X	X	X
Greenwood	X	X	X	X
Shorewood	X	X	X	X
Tonka Bay	X	X	X	X

Excelsior Permits: Contact the City of Excelsior Staff, 952-474-5233
<http://www.ci.excelsior.mn.us/index.aspx?NID=129>

Deephaven Issues Permits: Contact the City of Deephaven Staff, 952-358-9935
http://www.cityofdeephaven.org/index.asp?SEC=ABD263AC-540B-48D0-8B5B-B358E24EE30E&Type=B_BASIC

Greenwood Issues Permits: Contact City of Greenwood 952-474-6633
http://www.greenwoodmn.com/index.asp?SEC=C446C0E6-C85B-4D6B-9F2A-45390CDE8A69&Type=B_BASIC

Shorewood Permits: Contact the City of Shorewood Staff, 952-474-3236
<http://www.ci.shorewood.mn.us/pages/olforms/olforms.html>

Tonka Bay Issues Permits: Contact the City of Tonka Bay Staff, 952-474-7994
<http://www.cityoftonkabay.net/formsandpermits>

Occupancy must be classified before plans are reviewed.

Information required for occupancy classification:

Hours of operation

Primary function

Address of former location

On site sales

On line sales

Mission statement

Open to the public/access by the public

Current square footage of the building and any increase in square footage proposed for the building

Plans, as built plans, and permits must be on site at all times.

A rough in inspection will not be conducted without a plan review.

48 hours notice for rough in a final inspection.

Fire Sprinkler System

Plans must include data sheets and hydraulic calculations.

Plans required for 20 or more fire sprinkler head reconfigurations, additions and changes.

Fire Department Connections (FDC) 2 inch pipe or less a single FDC is allowed.

Fire Department Connection 3 inch or more requires a Siamese FDC.

Install metal caps or covers on Fire Department Connections. No plastic covers are allowed.

No locking Fire Department Connections are allowed unless owner provides FDC key and a Knox box at the FDC.

Exterior entrance to Sprinkler Riser Room preferred.

Residential Sprinkler Systems

Solenoid allowed and required on a residential well system unless they are a multipurpose system.

No shut off on residential riser unless they are a multipurpose system.

Residential sprinkler systems shut off must be installed before the meter.

No shut offs allowed after the meter.

The Excelsior Fire District recommends that a sprinkler head is placed above the staircase. This is a recommendation and not a requirement

Fire Alarm Systems

Fire alarm plans required for review.

Must be a UL certified alarm company.

Annunciator required at the main entrance.

Zone(s) required to be posted at the annunciator and alarm panel.

A horn and strobe is required on a commercial building.

The horn and strobe must activate between 45-60 seconds after water flows in commercial and residential buildings.

The fire alarm system must be on its own circuit and the circuit breaker must be identified in red "FIRE ALARM CIRCUIT".

General

A fire and police emergency Knox box (lock box) must be installed on a commercial building.

The address must be visible and legible-front and back of the building.

Revised: March 7, 2017